

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

CB TEST CERTIFICATE

Product

Industrial PC Power Supply Unit

Name and address of the applicant

ZIPPY TECHNOLOGY CORP
10f 50 Minquan Rd Xindian District
New Taipei, 231 Taiwan

Name and address of the manufacturer

ZIPPY TECHNOLOGY CORP
10f 50 Minquan Rd Xindian District
New Taipei, 231 Taiwan

Name and address of the factory

Note: When more than one factory, please report on page 2

ZIPPY TECHNOLOGY CORP
10f 50 Minquan Rd Xindian District
New Taipei, 231 Taiwan Additional Information on page 2

Ratings and principal characteristics

See Page 2

Trademark (if any)



Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PSM-5860V

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010, IEC 61010-2-201:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

E501793-D1000-1/A0/C0-CB issued on 2019-02-01

This CB Test Certificate is issued by the National Certification Body



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-03-04

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

DK-81156-UL

Ratings:

Input Rating: 100 to 240 Vac, 13 to 7 A, 47 to 63 Hz;

Output Rating: total outputs 860W; +12Vdc/60 A, +5Vdc/25A and +3.3Vdc/0-25A, +5Vsb/0-3.5A, -12Vdc/0-0.8A, total max. current of 5Vdc and +3.3Vdc output 40A

Additional Information:

Additionally evaluated to EN 61010-1:2010 and EN 61010-2-201:2018; National Differences specified in the CB Test Report.

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2019-03-04

Signature:

Jan-Erik Storgaard