



中国国家强制性产品认证证书

证书编号: 2012010907532951

委托人名称、地址

新巨企业股份有限公司
台湾省新北市新店区民权路50号10楼

生产者(制造商)名称、地址

新巨企业股份有限公司
台湾省新北市新店区民权路50号10楼

生产企业名称、地址

新巨企业股份有限公司五股厂
新北市五股区五权路48号4楼

产品名称和系列、规格、型号

开关电源

见附件: 仅适用于海拔2000米及以下

产品标准和技术要求

GB4943.1-2011; GB9254-2008 (A级); GB17625.1-2012

上述产品符合强制性产品认证实施规则
CNCA-01C-020: 2010的要求, 特发此证。

发证日期: 2017年02月08日

有效期至: 2022年02月08日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2012年03月23日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1575826



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2012010907532951

NAME AND ADDRESS OF THE APPLICANT

Zippy Technology Corp.
10F, No.50, Mincyuan Rd., Sindian Dist., New Taipei City, TAIWAN

NAME AND ADDRESS OF THE MANUFACTURER

Zippy Technology Corp.
10F, No.50, Mincyuan Rd., Sindian Dist., New Taipei City, TAIWAN

NAME AND ADDRESS OF THE FACTORY

Zippy Technology Corp.
4F., No. 48, Wucyuan Rd. Wugu Dist., New Taipei City 24886 Taiwan

NAME, MODEL AND SPECIFICATION

Power Supply and Power Module

见附件: 仅适用于海拔2000米及以下

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB4943.1-2011;GB9254-2008(Class A);GB17625.1-2012

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-020:2010).

Date of issue: Feb.08,2017 Date of expiry: Feb.08,2022

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Mar.23,2012

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejtiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



Q 1575826



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2012010907532951

纸号: 1575826

Model / 型号	Input/输入电压 (DC)	Input / 输入电流	Output Rated/输出规格 (DC)						
			+5V	+3.3V	+12V	+5VSB	-12V	+5V and +3.3V max/+5V 和 +3.3V 最大输出功率	Total max power/总最大输出功率
DM1U-2500V	-40V~ -72V	16-9A	/	/	41A	0-3A	/	/	500W
DM1U-2650V		20-12A	/	/	54A	0-3A	/	/	650W
DM1U-2750V		24-14A	/	/	62A	0-3A	/	/	750W
DM1U-2500V (D)		16-9A	/	/	41A	0-3A	/	/	500W
DM1U-2650V (D)		20-12A	/	/	54A	0-3A	/	/	650W
DM1U-2750V (D)		24-14A	/	/	62A	0-3A	/	/	750W

销售时不配电线组件

注: 此附录与证书同时使用时有效。



主 任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

